



### **Chemicals Approved for Use in Cooling Towers for Commercial/Industrial Facilities**

Chlorine  
Sulfuric Acid  
Peracetic Acid  
Hydrogen Peroxide  
Acetic Acid  
Phosphonic Acid  
Maleic Acid  
Hydroxyphosphono-acetic Acid  
Sodium Hydroxide  
Ethylenediaminetetraacetic acid

The following conditions apply to the use of the approved non-contact cooling water chemicals:

- The facility must provide adequate secondary containment or drain protection for all areas where the products will be used and stored.
- The facility must be prepared to clean-up spills of the non-contact cooling water products. If a spill occurs that discharges to sewer, please immediately contact the Wastewater Division at **888-3236** between 7:00 A.M. and 3:30 P.M. Monday through Friday and after hours please call 630-4069.
- The facility must insure that the pH of the cooling water discharge is between 5.0 and 11.0(Wenatchee City Code 4.08.08 (2)(b)) or the pH limit established under a State Waste Discharge permit from the Department of Ecology.
- This list may be updated. If you are interested in using a chemical not on this list, please contact the Environmental Division at 888-3235.